



Kerala Tourism Development Corporation Limited

(A Government of Kerala Undertaking)

P.B No.5424, Mascot Square, Vikas Bhavan P.O

Thiruvananthapuram –695 033, Kerala, India

Phone: ++91-471- 2721243/45/48, Fax: 2721249 Website:

www.ktdc.com

GST IN 32AABCK0385J1ZP, CIN U63040KL1965SGC002120

AE(E)1/KTDC/ROC/1029/2024-MGR

07-05-2025

RE-QUOTATION NOTICE

Sub: - Shifting of 20 kVA DG set from Aahaar Restaurant, Nellappara to Restaurant and Beer Parlour, Teekoy including installation, testing & commissioning works – Quotation Notice-reg.

Competitive offers are invited from reputed firms for electrical works related to shifting of existing 20 kVA DG set from Aahaar Restaurant, Nellappara to Restaurant and Beer Parlour, Teekoy including installation, testing & commissioning works as per the schedule attached and the following terms and conditions.

| Sl. No. | Name of Work | PAC | Time of completion | Eligibility |
|---------|--|---------------|--------------------|---|
| 1 | KTDC – Shifting of 20 kVA DG set from Aahaar Restaurant, Nellappara to Restaurant and Beer Parlour, Teekoy including installation, testing & commissioning works | Rs.1,46,000/- | 30 days | Eligible contractors who have executed two similar work costing not less than 1.15 Lakhs in past three years. Proof of valid contract license, supervisor permit and details of experience shall be submitted along with offer. |

Terms & Conditions

1. The rate shall be inclusive of GST, duties, loading, unloading charges, transportation, other incidental expenses and net for the work at site. No rate escalation will be allowed under any circumstances.
2. All statutory deductions will be deducted from the bill and exemptions if any shall be informed with supporting documents.
3. The bidders shall have valid license and required scope demanded by Kerala state Electricity Licensing Board.
4. The work shall be carried out in consultation with the KTDC officials

5. The work shall be completed within 30 days from the date of agreement executed.
6. The work has to be planned & completed without affecting the normal functioning of the Hotel.
7. All the works are to be carried out with good workmanship as per the latest code of practice in accordance with the rules and regulation of the Kerala State Electrical Inspectorate.
8. Payment Terms-100% payment will be released on full completion of all works at site.
9. The successful bidder shall execute an agreement in Kerala stamp paper worth Rs. 200/- with a Security Deposit of 5% of contract value for the fulfillment of contract. The security deposit will be released on expiry of defect liability period.
10. **The quotations shall be enclosed and submitted in a sealed envelope on which the name of work shall be clearly superscripted. Otherwise, the quotations will be summarily rejected.**

The offer shall reach the office of the Chief Engineer, KTDC Ltd, Mascot Square, Trivandrum – 695 033 on or before **15-05-2024, 2:30 PM.**

If the last date mentioned falls as a holiday or Hartal, the very next working day will be treated as the last date.

**SIKHA SURENDRAN IAS
MANAGING DIRECTOR**

Signed by
Laiju M G
Date: 07-05-2025 12:31:56



Kerala Tourism Development Corporation Limited

(A Government of Kerala Undertaking)

P.B No.5424, Mascot Square, Vikas Bhavan P.O

Thiruvananthapuram –695 033, Kerala, India

Phone:++91-471- 2721243/45/48, Fax: 2721249 Website:

www.ktdc.com

GST IN 32AABCK0385J1ZP, CIN U63040KL1965SGC002120

SHIFTING OF 20 KVA DG SET FROM AAHAAR NELLAPPARA TO RESTAURANT AND BEER PARLOUR, TEEKOY INCLUDING INSTALLATION, TESTING & COMMISSIONING WORKS - SCHEDULE

| Sl.No. | Qty | Description | Unit | Rate | Amount |
|--------|-----|--|-------------|------|--------|
| | | SHIFTING AND ERECTION OF EXISTING 20 kVA DG SET | | | |
| 1 | 1 | Charges for dismantling of existing 3 phase 20 kVA DG set including transportation, loading and unloading and moving the generator to the foundation including all other related accessories from KTDC Aahaar Nellpara to KTDC Restaurant and Beer Parlour Teekoy (around 30 KM distance) without any damages including installation testing & commissioning, cleaning, servicing, battery charging and petty repairs .(Note-Engine & Alternator are working condition). | Each | | |
| 2 | 10 | Supply and laying of one number additional PVC insulated and PVC sheathed armoured aluminium power cable of 1.1 kV grade of the following sizes in ground in the same trench in one tier horizontal formation including widening the trench by 20 cm, refilling the trench etc. as required but excluding sand cushioning and protective covering (in ordinary soil) 4 Core X 10 Sq.mm | m | | |
| | | Supply, laying and clamping of 1 no. PVC insulated and PVC sheathed armoured aluminium power cable, 1.1 KV grade of the following sizes using | | | |

| | | | | | |
|---|----|---|-----|--|--|
| 3 | 10 | clamps noted along with the cables, spacing of clamps not exceeding 60 cm, making good the damages , colour washing etc. as required. Supply, laying and clamping of 1 no. PVC insulated and PVC sheathed armoured aluminium power cable, 1.1 kV grade of the following sizes using clamps noted along with the cables, spacing of clamps not exceeding 60 cm, making good the damages , colour washing etc. as required. 4 core 10 sq mm with factory made clamp | | | |
| 4 | 4 | Supplying and making end termination with brass compression gland and aluminium lugs for following size of PVC insulated and PVC sheathed / XLPE aluminium conductor cable of 1.1 kV grade as required. 4 X 10 sq. mm (25mm) | Set | | |
| 5 | 10 | Charges for ground excavation (30 cm x 50 cm) for laying cable direct in ground and refilling the trench etc as required but excluding sand cushioning and protective covering | m | | |
| 6 | 1 | Supply and Installation of 63A 4 Pole change over switch in SS enclosure | no | | |
| 7 | 3 | Earthing with G.I. earth pipe 3 metre long, 40 mm dia including accessories, and providing masonry enclosure with cover plate having locking arrangement and watering pipe etc. (but without charcoal/ coke and salt) as required. | Set | | |
| 8 | 50 | Supply and drawing bare earthing conductors of the following sizes along with wiring/ cables and giving connection as required 3.15 mm copper conductor (10 SWG) | m | | |
| 9 | 2 | Providing and laying in position cement concrete 1:2:4 (1 cement : 2 coarse sand : 4 graded stone aggregate 20 mm nominal size) in foundation of pump, DG set etc | Cum | | |

| | | | | | |
|----|----|--|-----|--|--|
| | | including form work etc as required. | | | |
| 10 | 6 | Providing 15mm thick cement plaster of mix 1:4 (1 cement : 4 fine sand) at all levels. | Sqm | | |
| 11 | 3 | Supplying and fixing of MS, B Class exhaust gas pipe of dia. upto 100 mm conforming to IS:3589 cut to required lengths along with necessary bends, supports, clamps, anti-vibration mountings etc. as required up to the top of the nearest building as per pollution control board norms. | m | | |
| | | GENERATOR ROOFING | | | |
| 1 | 65 | Steel work in built up G I tubular (round, square or rectangular hollow tubes etc.) trusses etc., including cutting, hoisting,fixing in position and applying a priming coat of approved steel primer, including welding and bolted with special shaped washers etc. complete | Kg | | |
| 2 | 65 | Steel work for purlin/single section with G I pipes including cutting, hoisting, fixing in position and applying a priming coat of approved steel primer, including welding and bolted with special shaped washers etc. complete | Kg | | |
| 3 | 12 | Providing and fixing precoated galvanised iron profile sheets (size, shape and pitch of corrugation as approved by Engineer-in-charge) 0.50 mm (+0.05%), total coated thickness with zinc coating 120 grams per sqm as per IS: 277, in 240 mpa steel grade, 5-7 microns epoxy primer on both side of the sheet and polyester top coat 15-18 microns. Sheet should have protective guard film of 25 microns minimum to avoid scratches during transportation and should be supplied in single length upto 12 metre or as desired by Engineer-in-charge. The | Sqm | | |

| | | | | | |
|----|----|--|-----|--|--|
| | | sheet shall be fixed using self drilling/self tapping screws of size (5.5x55mm) with EPDM seal, complete upto any pitch in horizontal/ vertical or curved surfaces, excluding the cost of purlins, rafters and trusses and including cutting to size and shape wherever required | | | |
| 14 | 20 | Supply & laying of armoured copper cable of 1.1 KV grade of following size cable through trench/wall/ceiling. 3C x 2.5 sq mm | M | | |
| 15 | 2 | Providing cable glanding, gland earthing & end termination of UG cables of the 3C x 2.5 Sqmm sizes using Siemens type Brass compression gland & Copper lugs etc. complete | Set | | |
| | | GENERATOR ROOFING | | | |
| 16 | 60 | Steel work in built up G I tubular (round, square or rectangular hollow tubes etc.) trusses etc., including cutting, hoisting,fixing in position and applying a priming coat of approved steel primer, including welding and bolted with special shaped washers etc. complete | Kg | | |
| 17 | 60 | Steel work for purlin/single section with G I pipes including cutting, hoisting, fixing in position and applying a priming coat of approved steel primer, including welding and bolted with special shaped washers etc. complete | Kg | | |
| 18 | 12 | Providing and fixing precoated galvanised iron profile sheets (size, shape and pitch of corrugation as approved by Engineer-in-charge) 0.50 mm (+0.05%), total coated thickness with zinc coating 120 grams per sqm as per IS: 277, in 240 mpa steel grade, 5-7 microns epoxy primer on both side of the sheet and polyester top coat 15-18 microns. Sheet should have protective guard film of 25 microns minimum to avoid scratches during transportation and should be supplied in single length upto 12 metre or as desired by Engineer-in-charge. The | Sqm | | |

| | | | | | |
|---|--|---|----|--|--|
| | | sheet shall be fixed using self drilling/self tapping screws of size (5.5x55mm) with EPDM seal, complete upto any pitch in horizontal/ vertical or curved surfaces, excluding the cost of purlins, rafters and trusses and including cutting to size and shape wherever required. | | | |
| | | DG OPERATING SANCTION | | | |
| 1 | 1 | Preparation and submission of scheme drawings before the Electrical Inspectorate, obtaining approval, arranging inspection and obtaining sanction orders for the newly installed DG set etc. complete including statutory expenses. | LS | | |
| | GRAND TOTAL (INCLUSIVE OF GST) | | | | |

LAIJU M G

CHIEF ENGINEER

Signed by

Laiju M G

Date: 07-05-2025 12:32:46