

30	1	Supplying and fixing following rating, four pole, (three phase and neutral), 415 volts, residual current circuit breaker (RCCB), having a sensitivity current 30 mA in the existing MCB DB complete with connections, testing and commissioning etc. as required.25 amps	Nos		
31	3	Supplying and fixing following rating, four pole, (three phase and neutral), 415 volts, residual current circuit breaker (RCCB), having a sensitivity current 30 mA in the existing MCB DB complete with connections, testing and commissioning etc. as required.40 amps	Nos		
32	1	Charges for dismantling the existing MV panel, Metering cubicle etc from the current position including all cable connections and stack the materials in a suitable position as directed by the unit officials.	LS		
33	1	Charges for preparation of schematic drawing and obtaining sanction from electrical inspectorate and provide the total connected load to KSEB electrical section and regularize the load.(Statutory fees will be borne by KTDC)	LS		
TOTAL (Inclusive of GST)					

Handwritten signature
AEE

Handwritten signature
AEE (Ele)