

**Kerala Tourism Development Corporation Limited**

(A Government of Kerala Undertaking)

P.B No.5424, Mascot Square, Vikas Bhavan P.O

Thiruvananthapuram –695 033, Kerala, India

Phone: ++91-471- 2721243/45/48, Fax: 2721249 Website:

www.ktdc.com

GST IN 32AABCK0385J1ZP, CIN U63040KL1965SGC002120

AE(E)/KTDC/EW-TVM/393/HO-AC/2025

22-04-2025

QUOTATION NOTICE

Sub: - KTDC Corporate Office, Trivandrum - Electrical works related to SITC of inverter type Cassette AC / Split AC units in various sections–Quotation Notice – reg.

Competitive offers are invited from eligible contractors for the Electrical works related to SITC of inverter type Cassette AC / Split AC units in various sections at KTDC Corporate Office Trivandrum as per the schedule attached and the following terms and conditions.

Terms & Conditions

1. The rate shall be inclusive of GST, duties, loading, unloading charges, transportation, other incidental expenses and net for the work at site. No rate escalation will be allowed under any circumstances.
2. All statutory deductions will be deducted from the bill and exemptions if any shall be informed with supporting documents.
3. The bidders shall have valid B grade contractor license with supervisor permits demanded by Kerala state Electricity Licensing Board.
4. The work shall be carried out in consultation with the KTDC officials
5. The work shall be completed within 30 days from the date of receipt of order.
6. The work has to be planned & completed without affecting the normal functioning of the Hotel.
7. All the works are to be carried out with good workmanship as per the latest code of practice in accordance with the rules and regulation of the Kerala State Electrical Inspectorate.
8. The Materials used for the work shall be from the approved make of materials mentioned in BOQ.
9. Payment Terms-100% payment will be released on full completion of all works at site

The quotations shall be enclosed and submitted in a sealed envelope on which the name of work shall be clearly superscripted. Otherwise, the quotations will be summarily rejected.

The offer shall reach the office of the Chief Engineer, KTDC Ltd., Mascot Square,

Trivandrum – 695 033 on or before **28-04-2025, 2:30 PM.**

If the last date mentioned falls as a holiday or Hartal, the very next working day will be treated as the last date.

SIKHA SURENDRAN IAS
MANAGING DIRECTOR

Signed by

Laiju M G

Date: 23-04-2025 10:40:43



Kerala Tourism Development Corporation Limited

(A Government of Kerala Undertaking)

P.B No.5424, Mascot Square,Vikas Bhavan P.O

Thiruvananthapuram –695 033, Kerala, India

Phone:++91-471- 2721243/45/48, Fax: 2721249 Website:

www.ktdc.com

GST IN 32AABCK0385J1ZP, CIN U63040KL1965SGC002120

Electrical works related to SITC of inverter type Cassette AC / Split AC units in various sections					
Sl No	Qty	Description	Rate	Unit	Amount
1	1	Wiring for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable in surface / recessed medium class PVC conduit, with modular switch, modular plate, suitable GI box and earthing the point with 1.5 sq.mm. FRLS PVC insulated copper conductor single core cable etc as required. Group A		E	
2	2	Wiring for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable in surface / recessed medium class PVC conduit, with modular switch, modular plate, suitable GI box and earthing the point with 1.5 sq.mm. FRLS PVC insulated copper conductor single core cable etc as required. Group B		E	
3	25	Wiring for circuit/ sub main wiring along with earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface / recessed medium class PVC conduit as required 2x1.5 sq.mm + 1x1.5 sq.mm earth wire		m	
4	35	Wiring for circuit/ sub main wiring along with earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface / recessed medium class PVC conduit as required 2X 2.5 sq. mm + 1 X 2.5 sq. mm earth wire		m	
5	75	Wiring for circuit/ sub main wiring along with earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface / recessed medium class PVC conduit as required 2		m	

		X 4 sq. mm + 1 X 4 sq. mm earth wire			
6	15	Supplying and fixing of following sizes of medium class PVC conduit along with accessories in surface/recess including cutting the wall and making good the same in case of recessed conduit as required.20 mm		m	
7	15	Supplying and fixing of following sizes of medium class PVC conduit along with accessories in surface/ recess including cutting the wall and making good the same in case of recessed conduit as required. 25 mm		m	
8	2	Supplying and fixing following modular switch/ socket on the existing modular plate & switch box including connections but excluding modular plate etc. as required. 5/6 amps switch		E	
9	2	Supplying and fixing following modular switch/ socket on the existing modular plate & switch box including connections but excluding modular plate etc. as required. 15/16 amp switch		E	
10	2	Supplying and fixing following modular switch/ socket on the existing modular plate & switch box including connections but excluding modular plate etc. as required.3 pin 5/6 amp socket outlet		E	
11	2	Supplying and fixing following modular switch/ socket on the existing modular plate & switch box including connections but excluding modular plate etc. as required.6 pin 15/16 amp socket outlet		E	
12	2	Supplying and fixing following size/ modules, GI box along with modular base & cover plate for modular switches in recess etc as required.1 or 2 Module (75mm X 75mm)		E	
13	2	Supplying and fixing following Modular base & cover plate on existing modular metal boxes etc. as required.1 or 2 Module		E	
14	1	Supplying and fixing following Modular base & cover plate on existing modular metal boxes etc. as required.3 Module		E	
		Supplying and fixing following size/			

15	2	modules, GI box along with modular base & cover plate for modular switches in recess etc as required.3 Module (100mm X 75mm)		E	
16	4	Supply & Fixing the following types/sizes of boxes suitable for modular accessories in surface/ recess including making good the damages, colour washing etc as required (RoHS compliant) 2 module moulded plastic box on surface		E	
17	1	Supply & Fixing the following types/sizes of boxes suitable for modular accessories in surface/ recess including making good the damages, colour washing etc as required (RoHS compliant) 3 module moulded plastic box on surface		E	
18	6	Supplying and fixing modular blanking plate on the existing modular plate & switch box excluding modular plate as required		E	
19	2	Supply and Fixing the following modular switches & accessories in the existing front plates and giving necessary connections as required (RoHS compliant) 25A SP switch with indicator		E	
20	2	Supply and Fixing the following modular switches & accessories in the existing front plates and giving necessary connections as required (RoHS compliant) 25A 3pin Shuttered socket		E	
21	1	Supplying and fixing of following ways surface/ recess mounting, vertical type, 415 volts, TPN MCB required.)8 way (4 + 24), Double door distribution board of sheet steel, dust protected, duly powder painted, inclusive of 200 amps tinned copper bus bar, common neutral link, earth bar, din bar for mounting MCB's (but without MCB's and incomer) as required .(Note : Vertical type MCB TPDB is normally used where 3 phase outlets are required.) 8 way (4 + 24), Double door		E	
22	17	Supplying and fixing 5 amps to 32 amps rating, 240/415 volts, "C" curve, miniature circuit breaker suitable for inductive load of following poles in the		E	

		existing MCB DB complete with connections, testing and commissioning etc. as required. Single pole			
23	4	Supplying and fixing single pole blanking plate in the existing MCB DB complete etc. as required.		E	
24	2	Supplying and fixing following rating, double pole, 240 volts, isolator in the existing MCB DB complete with connections, testing and commissioning etc. as required.40 amps		E	
25	1	Supplying and fixing following rating, four pole, 415 volts, isolator in the existing MCB DB complete with connections, testing and commissioning etc. as required.63 amps		E	
26	2	Supplying and fixing 5 amps to 32 amps rating, 240/415 volts, "C" curve, miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required. Triple pole		E	
27	1	Supplying and fixing following rating, four pole, (three phase and neutral), 415 volts, residual current circuit breaker (RCCB), having a sensitivity current 30 mA in the existing MCB DB complete with connections, testing and commissioning etc. as required.63 amps		E	
28	1	Charges for dismantling the existing distribution boards/switch boards/Light fittings/fan/wires etc completely from the wall and closing the same if unwanted and finishing the surface neatly including stacking the materials and hand over to the unit.		L.S	
		TOTAL (Inclusive of GST & freight)			

LAIJU M G
CHIEF ENGINEER

Signed by
Laiju M G
Date: 23-04-2025 10:41:27

LIST OF APPROVED MAKES OF MATERIALS -ELECTRICAL		
Sl. No.	Material	Make
1	Modular Switches	Legrand, MK, L&T
2	PVC copper wires-FRLS	Finolex, Havells, V Guard, RR Kabel, Polycab
3	Distribution boards (IP 43)	Legrand, Schneider, Siemens, Hager, Indoasian
4	ELCB /MCB/RCCB/ RCBO/MCB COS/MPCB	Legrand, Schneider, Siemens, Hager, Indoasian
5	LT Cables	Gloster, Nicco, Havells, Finolex, RR, Polycab
6	LT Cable glands	Commex, Dowels
7	PVC Conduits	Avon plast, Balco, Circle arc, Precision
8	Casing/ Capping	Modi, Precision or equivalent approved
9	SDFU / SFU / TPN Isolators	L&T, Siemens, Schneider
12	Junction Boxes	Hensel, Cape Electric, Sintex

LAIJU M G
CHIEF ENGINEER

Signed by
Laiju M G
Date: 23-04-2025 10:39:59