



KERALA TOURISM DEVELOPMENT CORPORATION LTD

(A Government of Kerala Undertaking)

Engineering Wing, Mascot Square, Thiruvananthapuram -695 033

Phone: 2318976, 2721243 Fax: ++91-471-2316168

email-ce@ktdc.com website: www.ktdc.com

AE(E)1/KTDC.EW-TVM/699/MH-HT/2018

09-08-2021

QUOTATION NOTICE

Sub:- KTDC-Mascot Hotel, Trivandrum – Upgradation of HT metering system– Quotation- reg.

Competitive quotations are invited from reputed firms for the Upgradation of HT metering system at Mascot Hotel, Trivandrum as per the attached schedule and following terms and conditions.

Scope of work

The work includes dismantling of existing CT-PT units, TOD meter, supply, installation, testing and commissioning of new HT Indoor type 11kV metering CT- PT units, HT Bidirectional TOD meter.

Terms & Conditions

1. The rate quoted shall be inclusive of GST, cost of materials, labour charges, cost of consumables, loading charges, unloading charges, insurance, other incidental expenses and net for the work at site.
2. No escalation of rates will be allowed under any circumstances.
3. Materials and workmanship for the entire work shall be as per the latest code of practice and standards in force at the time of supply.
4. All the work shall be completed and TOD meter shall be commissioned within **45 days** from the date of executing agreement.
5. **The Contractor should have valid A grade contractor license with valid A grade supervisor permit with minimum scope of All LT/ MV, HT electrical installation, issued by Kerala state Electricity Licensing Board. The firm shall submit experience certificate of one similar works costing not less than Rs. 2.5 Lakhs.**
6. All Electrical installation / materials used shall be in accordance with the existing rules and regulations of the Electrical Inspectorate.
7. All details such as operation and maintenance manual, wiring diagram, spare parts list, tool kit etc shall be supplied for releasing the final payment.
8. The quantities given in the BOQ may vary as per the site requirement. The payment will be made to the actual quantities of materials used based on unit rates.
9. Necessary testing shall be carried out by the contractor after completion of the work without any additional cost.
10. The contractor has to engage a full time supervisor for the supervision, co-ordination and execution of the work.



